

Annexure C

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE**

No.

Date: 03.11.2025

It is certified that an inspection team headed by Dr. Santosh Mule, Zonal Health Officer from PMC Pune inspected the MIS International School, Balewadi, Pune 45 on 03.11.2025 and on the basis of water test report (Attached) bearing No. MITCON 2025-26/ September/241 dated 06.10.2025 of Mitcon consultancy & Engineering services Ltd. (PHED Lab) certified that the MIS International School, Balewadi, Pune 45 has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Govt.

This certificate is valid till 2/11/2026

Signature with seal:


Zonal Medical Officer
Health Dept. Zone No. 2
PMC

Name:

DR. Santosh Mule

Designation

Zonal Health Officer,
PMC, Pune

Name & Address of Office/Department:

Ghole Rd
zone-2 office,
PMC, Pune

To

MIS International School
Balewadi, Pune 411045

Note: The certificate is to be issued by authorized officer/PHED Lab/local bodies



GOVT. OF MAHARASHTRA

DEPUTY DIRECTOR, HEALTH SERVICES
STATE PUBLIC HEALTH LABORATORY, PUNE.
 Near St. Mary School And Church, Pune 411001



Telephone - Office :- (020) 263300225 Ext. 223

Email : statehealthlab@gmail.com

HEALTH SERVICES

NO. SPHL PUNE /Desk -79 / 389/ 2025. DATE :- 02/04/2025.

Report on Chemical Analysis of Drinking Water

Sent by :- Mis international School, Sr.no. 33/1, Opp. Chhatrapati shivaji sports Complex, Balewadi pune-411045.

With Ref. letter No :- 008

Dated :- 28/02 /2025

Date of Collection :- ----

Date of Receipt :- 28 /02/2025

Date of Examination :- 03/ 03/ 2025 onwards

(All the Analytical Results are in mg. / Lit. except pH , Turbidity)

SR · N O	TEST PARAMETER	S.No. - 1 (P-260) Drinking Water	BIS Specifications 10500 : 2012 Normal Values	
			Desirable limit	Permissible limit
1	Physical Appearance	Clear	---	---
2	Odour	agreeable	agreeable	agreeable
3	Turbidity (as N.T.U.)	0.64	1.0	5.0
4	pH Value	7.79	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	8.93	250	1000
6	Nitrates (as No3)	1.53	45	No relaxation
7	Total Hardness (as Caco3)	30.59	200	600
8	Alkalinity (as Caco3)	21.57	200	600
9	Total Dissolved Solids	49.9	500	2000
10	Iron (as Fe)	ND	1.0	No relaxation
11	Fluoride (as F)	ND	1.0	1.5

➤ ND :- Not detected.

➤ This report is restricted only for the sample /s submitted to this laboratory.

➤ It is presumed that the representative sample from the source is sent for analysis.

➤ This Sample /s is /are not collected by this laboratory .

Remark :- S.No. - 1 is chemically fit for drinking purpose on the basis of analysed parameters only.

However, this water source can be used for drinking purpose only after proper treatment, disinfection & ascertaining its bacteriological quality frequently or regularly.

Forwarded With Compliments To :- Mis international School, Sr.no. 33/1, Opp. Chhatrapati shivaji sports ,
Balewadi pune-411045.

Fees	600 /-
Receipt No.	5119205
Date	28/02/2025

Senior Scientific Officer
 State Public Health Laboratory
 Pune-411001